CITY OF NIAGARA FALLS
NEW YORK

April 10, 2018

TO: **Robert Zaleski**
Building Inspector

FROM: **Eric Palmer**
Chief Electrical Inspector

RE: **8251 Bollier**

An inspection was conducted at your request at the above referenced premises to determine what City Codified Ordinances and New York State Property Maintenance Code violations may exist at this time. The following is a list of electrical items that are to be addressed:

Exterior
-Replace Lower Service Entrance Cable
-Provide lighting for rear door

General
-Check the Electrical Service Equipment, all Devices, Fixtures and Wiring and Repair/Replace where Worn, Damaged or Missing. Provide GFCI and or Arc Fault protection where required by the 2014 NEC for any repairs, alterations or additional wiring.
-Check all Electric Baseboard Heating for proper installation and Safety

Kitchen
-Provide working space required in front of the breaker box that is currently buried by kitchen cabinets.

Smoke Detectors & Carbon Monoxide Detectors
-Install to code

Eric Palmer
Chief Electrical Inspector